



HWA-HSING

### ATTESTATION OF CONFORMITY

Attestation No.: HS5200-220624JH01-EU-01-R2

Issued To: Wuxi Solinteg Power Co., Ltd.

Applicant Address: Building H1-1001, No. 6 Jingxian Road, Xinwu District, 214135 Wuxi, Jiangsu Province, China

Product(s): HYBRID INVERTER

Brand(s): Solinteg

Model(s): MHT-20K-40, MHT-4K-25, MHT-5K-25, MHT-6K-25, MHT-8K-25, MHT-10K-25, MHT-12K-25, MHT-10K-40, MHT-12K-40, MHT-15K-40

Power Characteristics Rated DC input voltage: DC 620V 30A\*2  
Rated AC output voltage: 3L/N/PE, 220/380V; 230/400V;  
(MHT-20K-40): 240/415V~33.5A

**We, Hwa-Hsing (Dongguan) Testing Co., Ltd.,  
Declare that the submitted sample of the above has been tested for CE marking according  
to following standard(s) of the European Directive:**

**- Radio Equipment Directive (RED) 2014/53/EU**

Essential Requirement	Standards	Report No.
Article 3.1(a) safety	IEC/EN 62109-1:2010 IEC/EN 62109-2:2011	WT223201967
Article 3.1(b) EMC	EN 55011:2016/A2:2021; CISPR 11:2015/AMD2:2019; EN IEC 61000-6-1:2019; EN IEC 61000-6-2:2019; EN IEC 61000-6-3:2021; EN IEC 61000-6-4:2019; EN IEC 61000-3-2:2019+A1:2021; EN 61000-3-12:2011; IEC 61000-3-12:2011+AMD1:2021; EN IEC 61000-3-11:2019; EN 61000-3-3:2013/A2:2021; IEC 61000-3-3:2013/AMD2:2021	220624JH01-RE-EU-01-R1

The referred test report(s) show that the product complies with standard(s) recognized as giving presumption of compliance with the essential requirements.

This ATTESTATION does not imply assessment of the production of the product.



This document shall not be reproduced, except in full, without the written approval of Hwa-Hsing (Dongguan) Testing Co., Ltd.  
Information given in this document, are related to the tested specimen of the described electrical sample.